



MEGHALAYA ENERGY CORPORATION IMITED

OFFICE OF THE ADDITIONAL CHIEF ENGINEER (EL)

MATERIAL MANAGEMENT

LUM JINGSHAI; SHORT ROUND ROAD; SHILLONG-793001

Phone – 0364-2591930 E-mail: ace.mm.meecl@gmail.com Fax- 0364- 2590955

Purchase, Estimate & Issue rate of Circuit Breakers, SF6 Gas, 11KV VCB Panels.

SI No.	Item Description	Unit	Purchase Rate (₹)	Rate inclusive of ED, CST & F&I. (₹)	Issue Rate (Estimate rate + Storage & handling Charges @7.5%)
1	145 KV, 40KA, SF6 Circuit Breaker with breaking capacity of 2500 MVA and continuous rating of 800 Amps along with mounting structure & Bimetalic rigid type terminal connectors for connecting with ACSR Panther conductor DC volts 220V, CB with spray accessories, foundation bolts etc & also with first filling of SF6 gas.	No	552000.00	661020.00	710596.50
2	3 Ph, 50 HZ, 33KV, 800A, 25KA, Outdoor type Vacuum Circuit Breaker with galvanised mounting structure and foundation Bolt PCOB-36, DC supply - 220V.	No	245000.00	293387.50	315391.56
3	36 KV, 1250A, SF6 Circuit Breaker 25KA, type 30SFPG with mounting structure & Bimetalic rigid type terminal connectors for connecting with ACSR Panther conductor DC volts 110V, CB with spray accessories, foundation bolts etc & also with first filling of SF6 gas.	No	270000.00	323325.00	347574.38
4	SF6 Gas Cylinder as per IS.	Kg	4350.00	4350.00	4676.25
5	CGL make 11KV Indoor VCB Panel, CT Ratio 200-100/5/5 A	No	373235.00	373235.00	401227.63
6	CGL make 11KV Indoor VCB Panel, CT Ratio 50-100/5/5 A	No	328426.00	328426.00	353057.95