



# MEGHALAYA ENERGY CORPORATION IMITED

OFFICE OF THE ADDITIONAL CHIEF ENGINEER (EL)

MATERIAL MANAGEMENT

LUM JINGSHAI; SHORT ROUND ROAD; SHILLONG-793001

*Phone – 0364-2591930 E-mail: ace.mm.meecl@gmail.com Fax- 0364- 2590955*

## Purchase, Estimate & Issue rate of LTAC Switchgear

SI No.	Item Description	Unit	Purchase Rate. (₹)	Estimate rate inclusive of ED, CST & F&I. (₹)	Issue Rate (Estimate rate + Storage & handling Charges @7.5%) (₹)
1	LT AC Switchgear with 1 nos incomer of 400A capacity & 6 nos outgoing feeders of 63A capacity + 2 nos outgoing feeders of 16A capacity complete with MCCB's and other items as per bill of materials enclosed at Annexure -II and fitted with AI. Bus bar to be housed inside a cubicle made of 2 mm CGRA Sheet.	No	234300.00	238986.00	256909.95
2	Indoor typr sectionalised 415V Metal Enclosed LT AC Panel for auxiliary and station service with incoming & outgoing feeders as per diagram complete with L&T make MCCB's and MCB's, Aluminium bus bar rated for 400A continuous current, measuring and indication instruments of AE/ Rishab or reputed make.	No	712500.00	726750.00	781256.25
3	LT AC Switchgear with 2 nos incomer of 800A capacity & 6 nos outgoing feeders of 200A capacity complete with MCCB or ACB and other items as per bill of materials enclosed at Annexure -II and fitted with AI. Bus bar to be housed inside a cubicle made of 2 mm CGRA Sheet, along with Supervision charges for installation & comissioning.	No	685000.00	698700.00	751102.50