



MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED
OFFICE OF THE CHIEF ENGINEER (DISTRIBUTION)
SHORT ROUND ROAD, LUMJINGSHAI,
SHILLONG-793001, MEGHALAYA

Phone: (0364) 2590229 Fax: 03642591174 CIN: U40101ML2009SGC008374 email: cedist.mepdcl@gmail.com

No. MePDCL/ CE(D)/T-476(Q)/IPDS/ 2017-18/07

Dated 23rd March 2018

CORRIGENDUM

Corrigendum is hereby published against the Tender No. MePDCL/CE(Dist)/T-476(Q)/IPDS/2017-18/1 Dated 6th March 2018. This corrigendum shall supersede the earlier requirement of UC compliance switch issued vide Letter No. MePDCL/CE(Dist)/T-476(Q)/2017-18/06 dated 22nd March 2018 .

Sl. No.	Clause No & Title	Queries	Clarification/Amendments	Corrigendum
7	Clause no 2.14, Vol-III Sec-1_TSA_Meter	Request to clarify disconnection switch: (Single phase key pad Pre-Payment Meter): Switch shall be compliance with UC-2 in all aspects.	The meter shall have disconnection switch/relays with remote connect/disconnect facilities in both phase and neutral to disconnect the load incase of zero balance. The switch shall be connected only after meter is credited with sufficient balance and should not be closed by any others means. Switch shall be compliance with UC-2 or better .	The meter shall have disconnection switch/relays with remote connect/disconnect facilities in both phase and neutral to disconnect the load incase of zero balance. The switch shall be connected only after meter is credited with sufficient balance and should not be closed by any others means. Switch shall be compliance with UC-1 or better .

K N War
23/3/18
(K N War)

Chief Engineer (Distribution)

Memo No. MePDCL/ CE(D)/T-476(Q)/IPDS/2017-18/07 (a)

Dated 23rd March 2018

Copy to:

1. The Director (Distribution) MePDCL, Shillong for his kind information.
2. The Additional Chief Engineers (Eastern Zone/Western Zone), MePDCL, Shillong / Tura.
3. The Chief Engineer (Commercial), MeECL, Shillong, with a request to post these corrigendum in the website <http://www.meghalayatenders.gov.in>. and also in MeECL website.
4. All members of the Tender Evaluation Committee.
5. All intending bidders present.

K N War
23/3/18
Chief Engineer (Distribution)