

# MEGHALAYA POWER DISTRIBUTION CORPORATION Ltd

OFFICE OF THE CHIEF ENGINEER (DISTRIBUTION),  
SHORT ROUND ROAD, LUM JINGSHAI  
SHILLONG-793001, MEGHALAYA  
CIN: U40101ML2009SGC008394

RE (MIS)  
The MPA

No.MePDCL/CE(dist)/T476(Q)/IPDS/2017-18/16

Dated the 2<sup>nd</sup> May 2018 2/5

Minutes of the TEC on Technical Evaluation for Supply & installation of Prepaid meter under Integrated Power Development Scheme (IPDS) Vide Tender No.MePDCL/CE(dist)/T476(Q)/IPDS/2017-18/1 held on 2<sup>nd</sup> May 2018 at 11:00 am in the Conference Hall, Lum Jingshai, MeECL, Shillong.

Officers present as per Annexure A

At the outset, the Chief Engineer (Distribution), Chairman of the Tender Evaluation Committee, welcomed all the members present in the TEC meeting on 2.5.2018. It was informed that the meeting is meant for the Techno Commercial Evaluation of the Bid for prepaid meter. The Techno-commercial Bid for the above mentioned tender was opened on 3/4/2018. He further informed that the queries during evaluation are received from the participated bidders and after reviewing of submitted documents a comparative statement of the evaluation has been prepared.

The committee had a thorough discussion on the comparative statement & compared the parameters/criteria given in the Tender Specifications and those offered by the bidders. The following decision was taken after the discussion:

Total three (3 Nos) bidders have participated in the Tender and the observations are as follows:

1. M/s Genus Power Infrastructure Ltd, Jaipur 302022: All submitted documents found in order as per tender specification. Hence, the bid found responsive.
2. M/s Secure Meter Ltd, Udaipur 313003: All submitted documents found in order as per tender specification. Hence, the bid found responsive.
3. M/s Sinhal Udyog, Delhi 110041: The firm has submitted documents and the observations are as follows:
  - I. Turnover of the firm in the FY 2014-15 is Rs.19.31 Cr out of the required criteria Rs.20.00 Cr.
  - II. Liquid Asset submitted is Rs.39.00 lakh out of the requirement of Rs. 42.5 Lakh.
  - III. The Type test report submitted as per IS 13779 for 3-ph meter is 10-60 A range, whereas the required criteria for 3-ph meter is 20-80 A.
  - IV. The Type test report submitted as per IS 15959 is 5-30 A range for 1-Ph meter, whereas the required criteria is 10-60 A.
  - V. The Type test report of IS 15959 for 3-ph meter as per required criteria is not submitted.
  - VI. Qualification of bidder as per SBD Vol I sec II of ITB, Clause no.2.4 (f), was not submitted.

From the above it may be seen that the Bid submitted by M/s Sinhal Udyog is not responsive and hence disqualify from financial bid opening.

Based on the observations, TEC has decided to open financial Bid of the following qualified bidders:

1. M/s Genus Power Infrastructure Ltd, Jaipur.
2. M/s Secure Meter Ltd, Udaipur.

TEC also decided to open the financial bid of the qualified bidders on 04/05/2018 at 4.30 pm in the Conference Hall, Lumjingshai. The minutes of the Technical evaluation meeting shall be uploaded in the website [www.meghalayatenders.gov.in](http://www.meghalayatenders.gov.in) as well as in MeECL website for the information to the qualified bidders for their presence during opening of financial bid.

Since no further issues pertaining to the technical evaluation are pending, the meeting ended with a vote of thanks from the chair.

*K N War*  
(K N War)  
Chief Engineer (Distribution)  
Dated the 2<sup>nd</sup> May 2018.

Memo No. MePDCL/CE(dist)/T476(Q)/IPDS/2017-18/16  
Copy to:

1. The Director (Distribution) MePDCL, Shillong for his kind information.
2. The Chief Engineer (Commercial), MeECL.
3. The Additional Chief Engineers (Eastern Zone/Western Zone), MePDCL, Shillong / Tura.
4. The Additional Chief Engineer (Commercial), MeECL, Shillong, with a request to post this Minute in the website <http://www.meghalayatenders.gov.in> and also in MeECL website.
5. All members of the Tender Evaluation Committee.
6. All Qualified bidders, for their presence during opening of Financial Bid on 04.05.2018 at 4.30 PM in the Conference hall of MeECL, Lumjingshai.

*K N War*  
Chief Engineer (Distribution)

