



MEGHALAYA ENERGY CORPORATION LIMITED  
OFFICE OF THE ADDITIONAL CHIEF ENGINEER (EL)  
MATERIAL MANAGEMENT  
LUM JINGSHAI; SHORT ROUND ROAD; SHILLONG-793001  
CIN : U40101ML2009SGC008274

Phone – 0364-2591930

✉: [ace.mm.meecl@gmail.com](mailto:ace.mm.meecl@gmail.com)

CORRIGENDUM-3


Tender No. MeECL/ACE(MM)/2018-19/5

For Package-I, the CTs and PTs should be any of the following make:

1. M/s Pragati Electricals Pvt. Ltd.
2. M/s Laxmi Engineering
3. Vishal Transformers & Switchgears Pvt. Ltd.

For Package-II,

1. the words “33KV Lighting Arrestor, Station Type” appearing in the Price Schedule may be read as “33KV Lighting Arrestor, Class-II, Station Type along with Surge Counters. Insulating Base and Base Plates”.
2. The words “11Kv lightning Arrestor, Line Type” appearing in the Price Schedule may be read as “11Kv Lightning Arrestor, Class-II. Line Type”.
3. A new sub clause 1.1. under 2.0 scope of supply: in the section- 3. Technical Specification for TECHNICAL SPECIFICATION FOR G.I. CHEMICAL EARTH ELECTRODE WITH EARTH ENHANCING COMPOUND Is inserted as here under:
  - 1.1. Chemical Earthing should be perforated type with the terminal connectors to be provided at its one of the tips so that the 24mm Ø Bolt/ Nuts can be fitted accordingly. The chemical should be compatible to be re-filled around the Electrode as and whenever desired.
  - 1.2. The Chemical Electrode shall be 2.0m long 50mm dia with 2.89 mm wall thickness.
  - 1.3. The Chemical Compound shall be supplied with 25kg B.F.C.

  
Additional Chief Engineer (MM)  
MeECL., Shillong

Dated 02/11/2018

Memo No. ACE(MM)/1003/2017-18/143

Copy to:

1. The Additional Chief Engineer (Comm), MePDCL, Shillong. He is requested to incorporate the above Notice in the MeECL website.

Additional Chief Engineer(MM)