

Name of the Hydro Generating Station: Umtru Power Station

DESIGN ENERGY AND MW CONTINUOUS(Monthwise) - RUN OF RIVER TYPE STATIONS

Installed Capacity : No. of Units X. MW = 4 x 2.8

Installed Capacity : 16.97 Units x 111.4 x 2.0							2016-17 (Estimated)		2017-18 (Projected)		2018-19 (Projected)		2019-20 (Projected)	
Year :			2014-15 (Actual)		2015-16 (Actual)		April to September (Actual) October to March (Projected)							
S.No	Month	Units	Design Energy (Mus)	Continuous MW	Design Energy (Mus)	Continuous MW	Design Energy (Mus)	Continuous MW	Design Energy (Mus)	Continuous MW	Design Energy (Mus)	Continuous MW	Design Energy (Mus)	Continuous MW
1	April	I	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
		II	1.42	1.97	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
		III	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
		IV	0.56	0.75	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
2	May	I	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
		II	1.49	2.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
		III	0	0.00	0.33	0.46	0	0.00	0	0.00	0	0.00	0	0.00
		IV	0.77	1.03	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
3	June	I	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
		II	0.53	0.71	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
		III	0	0.00	0.15	0.21	0	0.00	0	0.00	0	0.00	0	0.00
		IV	0.36	0.48	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
4	July	I	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
		II	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
		III	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
		IV	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
5	August	I	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
		II	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
		III	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
		IV	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
6	September	I	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
		II	1.19	1.60	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
		III	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
		IV	1.13	1.52	0.92	1.28	0	0.00	0	0.00	0	0.00	0	0.00
7	October	I	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
		II	1.53	2.06	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
		III	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
		IV	1.29	1.73	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
8	November	I	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
		II	1.14	1.53	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
		III	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
		IV	0.34	0.46	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
9	December	I	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
		II	0.19	0.26	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
		III	1.12	1.51	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
		IV	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
10	January	I	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
		II	0.39	0.52	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
		III	1.01	1.36	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
		IV	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
11	February	I	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
		II	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
		III	0.75	1.12	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
		IV	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
12	March	I	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
		II	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
		III	0.37	0.50	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
		IV	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
	Total		15.58	21.11	1.4	1.94	0	0.00	0	0.00	0	0.00	0	0.00



Name of the Hydro Generating Station: Stage - I Power Station

DESIGN ENERGY AND PEAKING CAPABILITY (Monthwise)- PONDAGE/STORAGE TYPE STATIONS.

Installed Capacity : No. of Units X. MW = 9 x 4

Installed Capacity : No.of Units X. MW= 9 x 4							2016-17 (Estimated) April to September (Actual) October to March (Projected)		2017-18 (Projected)		2018-19 (Projected)		2019-20 (Projected)	
Year :			2014-15 (Actual)		2015-16 (Actual)									
Sl. No	Month	Units	Design Energy (Mus)	Continuous MW	Design Energy (Mus)	Continuous MW	Design Energy (Mus)	Continuous MW	Design Energy (Mus)	Continuous MW	Design Energy (Mus)	Continuous MW	Design Energy (Mus)	Continuous MW
1	April	I	0.81	1.13	1.22	1.69	2.04	2.83	1.13	1.57	1.13	1.57	1.13	1.57
		II	1.14	1.58	2.11	2.93	2.43	3.38	1.13	1.57	1.13	1.57	1.13	1.57
		III	0.95	1.32	1.91	2.65	2.04	2.83	1.13	1.57	1.13	1.57	1.13	1.57
		IV	1.19	1.65	1.34	1.86	2.47	3.43	1.13	1.57	1.13	1.57	1.13	1.57
2	May	I	0.91	1.22	2.45	3.29	1.52	2.04	1.00	1.34	1.00	1.34	1.00	1.34
		II	1.28	1.72	2.44	3.28	1.89	2.54	1.00	1.34	1.00	1.34	1.00	1.34
		III	1.02	1.37	0.00	0.00	1.35	1.81	1.00	1.34	1.00	1.34	1.00	1.34
		IV	1.13	1.52	0.00	0.00	1.97	2.65	1.00	1.34	1.00	1.34	1.00	1.34
3	June	I	0.69	0.96	2.34	3.25	3.18	4.42	1.63	2.26	1.63	2.26	1.63	2.26
		II	0.66	0.92	2.59	3.60	3.37	4.68	1.63	2.26	1.63	2.26	1.63	2.26
		III	0.69	0.96	1.23	1.71	3.19	4.43	1.63	2.26	1.63	2.26	1.63	2.26
		IV	1.05	1.46	1.35	1.88	3.35	4.65	1.63	2.26	1.63	2.26	1.63	2.26
4	July	I	0.19	0.26	2.33	3.13	3.95	5.31	2.50	3.36	2.50	3.36	2.50	3.36
		II	0.87	1.17	2.16	2.90	3.83	5.15	2.50	3.36	2.50	3.36	2.50	3.36
		III	0.69	0.93	1.65	2.22	3.91	5.23	2.50	3.36	2.50	3.36	2.50	3.36
		IV	0.67	0.90	2.59	3.48	4.03	5.42	2.50	3.36	2.50	3.36	2.50	3.36
5	August	I	1.43	1.92	3.16	4.25	5.11	6.87	3.00	4.03	3.00	4.03	3.00	4.03
		II	1.49	2.00	2.98	4.01	4.95	6.65	3.00	4.03	3.00	4.03	3.00	4.03
		III	1.49	2.00	2.71	3.64	5.09	6.84	3.00	4.03	3.00	4.03	3.00	4.03
		IV	1.45	1.95	3.07	4.13	4.99	6.71	3.00	4.03	3.00	4.03	3.00	4.03
6	September	I	4.28	5.94	6.15	8.54	1.87	2.60	4.25	5.90	4.25	5.90	4.25	5.90
		II	4.29	5.96	5.99	8.32	1.77	2.46	4.25	5.90	4.25	5.90	4.25	5.90
		III	4.47	6.21	5.94	8.25	1.91	2.65	4.25	5.90	4.25	5.90	4.25	5.90
		IV	4.38	6.08	6.17	8.57	1.85	2.57	4.25	5.90	4.25	5.90	4.25	5.90
7	October	I	3.49	4.69	2.84	3.82	3.75	5.04	3.75	5.04	3.75	5.04	3.75	5.04
		II	3.74	5.03	4.44	5.97	3.75	5.04	3.75	5.04	3.75	5.04	3.75	5.04
		III	3.56	4.78	3.89	5.23	3.75	5.04	3.75	5.04	3.75	5.04	3.75	5.04
		IV	4.05	5.44	3.94	5.30	3.75	5.04	3.75	5.04	3.75	5.04	3.75	5.04
8	November	I	1.25	1.74	1.29	1.79	2.50	3.47	2.50	3.47	2.50	3.47	2.50	3.47
		II	1.51	2.10	1.69	2.35	2.50	3.47	2.50	3.47	2.50	3.47	2.50	3.47
		III	1.62	2.25	1.15	1.60	2.50	3.47	2.50	3.47	2.50	3.47	2.50	3.47
		IV	1.58	2.19	1.73	2.40	2.50	3.47	2.50	3.47	2.50	3.47	2.50	3.47
9	December	I	2.51	3.37	1.63	2.19	2.25	3.02	2.50	3.36	2.50	3.36	2.50	3.36
		II	2.65	3.56	1.65	2.22	2.25	3.02	2.50	3.36	2.50	3.36	2.50	3.36
		III	2.37	3.19	1.51	2.03	2.25	3.02	2.50	3.36	2.50	3.36	2.50	3.36
		IV	2.89	3.88	1.75	2.35	2.25	3.02	2.50	3.36	2.50	3.36	2.50	3.36
10	January	I	1.31	1.76	2.37	3.19	1.75	2.35	2.00	2.69	2.00	2.69	2.00	2.69
		II	1.70	2.23	2.55	3.43	1.75	2.35	2.00	2.69	2.00	2.69	2.00	2.69
		III	1.26	1.69	1.21	1.63	1.75	2.35	2.00	2.69	2.00	2.69	2.00	2.69
		IV	1.79	2.41	0.98	1.29	1.75	2.35	2.00	2.69	2.00	2.69	2.00	2.69
11	February	I	1.76	2.62	1.32	1.90	1.75	2.60	1.75	2.60	1.75	2.60	1.75	2.51
		II	0.16	0.24	1.37	1.97	1.75	2.60	1.75	2.60	1.75	2.60	1.75	2.51
		III	1.41	2.10	0.76	1.08	1.75	2.60	1.75	2.60	1.75	2.60	1.75	2.51
		IV	1.82	2.71	2.01	2.89	1.75	2.60	1.75	2.60	1.75	2.60	1.75	2.51
12	March	I	1.70	2.28	1.95	2.62	1.50	2.02	1.50	2.02	1.50	2.02	1.50	2.02
		II	1.76	2.37	3.04	4.09	1.50	2.02	1.50	2.02	1.50	2.02	1.50	2.02
		III	2.67	3.59	2.82	3.79	1.50	2.02	1.50	2.02	1.50	2.02	1.50	2.02
		IV	2.81	3.78	2.29	3.08	1.50	2.02	1.50	2.02	1.50	2.02	1.50	2.02
Total			88.59	121.18	114.04	155.77	122.31	172.11	100.04	150.62	110.04	150.62	110.04	150.26



Name of the Hydro Generating Station: Stage - II Power Station

DESIGN ENERGY AND PEAKING CAPABILITY (Monthwise)- PONDAGE/STORAGE TYPE STATIONS.

Installed Capacity : No. of Units X. MW = 2 x 10

Year :		2014-15 (Actual)		2015-16 (Actual)		2016-17 (Estimated) April to September (Actual) October to March (Projected)		2017-18 (Projected)		2018-19 (Projected)		2019-20 (Projected)		
Sl No	Month	Units	Design Energy (Mus)	Continuous MW	Design Energy (Mus)	Continuous MW	Design Energy (Mus)	Continuous MW	Design Energy (Mus)	Continuous MW	Design Energy (Mus)	Continuous MW	Design Energy (Mus)	Continuous MW
	April	I	0.28	0.39	1.52	2.11	3.22	4.47	1.35	1.88	1.35	1.88	1.35	1.88
		II	1.86	2.58	1.98	2.75	1.54	2.14	1.35	1.88	1.35	1.88	1.35	1.88
2	May	I	0.39	0.52	0.00	0.00	2.61	3.51	1.15	1.55	1.15	1.55	1.15	1.55
		II	1.97	2.65	2.58	3.47	0.98	1.32	1.15	1.55	1.15	1.55	1.15	1.55
3	June	I	0.34	0.47	1.18	1.64	4.44	6.17	1.50	2.08	1.50	2.08	1.50	2.08
		II	1.33	1.85	2.82	3.92	2.54	3.53	1.50	2.08	1.50	2.08	1.50	2.08
4	July	I	0.32	0.43	1.58	2.12	4.84	6.51	1.50	2.02	1.50	2.02	1.50	2.02
		II	1.15	1.55	3.07	4.13	3.58	4.81	1.50	2.02	1.50	2.02	1.50	2.02
5	August	I	1.18	1.59	2.69	3.62	4.61	6.20	3.00	4.03	3.00	4.03	3.00	4.03
		II	1.78	2.39	3.43	4.61	5.12	6.88	3.00	4.03	3.00	4.03	3.00	4.03
6	September	I	4.21	5.85	6.34	8.81	1.59	2.21	3.50	4.86	3.50	4.86	3.50	4.86
		II	4.43	6.15	5.93	8.24	2.39	3.32	3.50	4.86	3.50	4.86	3.50	4.86
7	October	I	3.09	4.15	3.04	4.09	3.50	4.70	3.50	4.70	3.50	4.70	3.50	4.70
		II	4.18	5.62	4.43	5.95	3.50	4.70	3.50	4.70	3.50	4.70	3.50	4.70
8	November	I	0.98	1.36	0.51	0.71	2.50	3.47	3.00	4.17	3.00	4.17	3.00	4.17
		II	1.99	2.76	2.37	3.29	2.50	3.47	3.00	4.17	3.00	4.17	3.00	4.17
9	December	I	3.47	4.66	1.21	1.63	1.50	2.02	3.00	4.03	3.00	4.03	3.00	4.03
		II	1.01	2.45	2.00	2.69	1.50	2.02	3.00	4.03	3.00	4.03	3.00	4.03
10	January	I	2.92	3.92	3.28	4.41	1.50	2.02	2.00	2.69	2.00	2.69	2.00	2.69
		II	0.19	0.26	0.29	0.39	1.50	2.02	2.00	2.69	2.00	2.69	2.00	2.69
11	February	I	3.12	4.64	0.44	0.63	1.50	2.23	2.00	2.98	2.00	2.98	2.00	2.87
		II	0.13	0.19	2.33	3.35	1.50	2.23	2.00	2.98	2.00	2.98	2.00	2.87
12	March	I	3.21	4.31	3.46	4.65	1.50	2.02	2.00	2.69	2.00	2.69	2.00	2.69
		II	1.46	2.03	1.74	2.42	1.50	2.02	2.00	2.78	2.00	2.78	2.00	2.78
	Total		45.8	62.78	58.22	79.60	61.46	83.97	55.00	75.43	55.00	75.43	55.00	75.22



Name of the Hydro Generating Station: Stage - III Power Station

DESIGN ENERGY AND PEAKING CAPABILITY (Monthwise)- PONDAGE/STORAGE TYPE STATIONS.

Installed Capacity : No. of Units X. MW = 2 x 30

Year :		2014-15 (Actual)		2015-16 (Actual)		2016-17 (Estimated) April to September (Actual) October to March (Projected)		2017-18 (Projected)		2018-19 (Projected)		2019-20 (Projected)		
S.No	Month	Units	Design Energy (Mus)	Continuous MW	Design Energy (Mus)	Continuous MW	Design Energy (Mus)	Continuous MW	Design Energy (Mus)	Continuous MW	Design Energy (Mus)	Continuous MW	Design Energy (Mus)	Continuous MW
1	April	I	0.00	0.00	0.00	0.00	0.00	0.00	3.00	4.17	3.00	4.17	3.00	4.17
		II	2.77	3.85	8.04	11.17	9.84	13.67	1.00	1.39	1.00	1.39	1.00	1.39
2	May	I	0.00	0.00	0.00	0.00	0.00	0.00	2.00	2.69	2.00	2.69	2.00	2.69
		II	4.87	6.55	8.94	12.02	10.37	13.94	5.00	6.72	5.00	6.72	5.00	6.72
3	June	I	0.00	0.00	0.00	0.00	0.00	0.00	2.00	2.78	2.00	2.78	2.00	2.78
		II	7.54	10.47	10.79	14.99	0.00	0.00	6.00	8.33	6.00	8.33	6.00	8.33
4	July	I	0.00	0.00	0.00	0.00	0.00	0.00	2.00	2.69	2.00	2.69	2.00	2.69
		II	10.38	13.95	13.57	18.24	0.00	0.00	10.00	13.44	10.00	13.44	10.00	13.44
5	August	I	0.00	0.00	0.00	0.00	1.29	1.73	3.00	4.03	3.00	4.03	3.00	4.03
		II	14.09	18.94	14.66	19.70	0.00	0.00	10.00	13.44	10.00	13.44	10.00	13.44
6	September	I	0.00	0.00	0.00	0.00	0.15	0.21	4.00	5.56	4.00	5.56	4.00	5.56
		II	11.06	15.36	10.98	15.25	2.93	4.07	10.00	13.89	10.00	13.89	10.00	13.89
7	October	I	0.00	0.00	0.00	0.00	3.00	4.03	5.00	6.72	5.00	6.72	5.00	6.72
		II	18.39	24.72	11.32	15.22	12.00	16.13	10.00	13.44	10.00	13.44	10.00	13.44
8	November	I	0.00	0.00	0.00	0.00	2.00	2.78	8.00	11.11	8.00	11.11	8.00	11.11
		II	7.99	11.10	9.35	12.99	8.00	11.11	2.00	2.78	2.00	2.78	2.00	2.78
9	December	I	0.00	0.00	0.00	0.00	2.00	2.69	3.00	10.75	8.00	10.75	8.00	10.75
		II	8.62	11.59	6.06	8.15	9.00	12.10	2.00	2.69	2.00	2.69	2.00	2.69
10	January	I	0.00	0.00	0.00	0.00	2.00	2.69	7.00	9.41	7.00	9.41	7.00	9.41
		II	8.94	12.02	9.03	12.14	8.00	10.75	3.00	4.03	3.00	4.03	3.00	4.03
11	February	I	0.00	0.00	0.00	0.00	2.00	2.98	6.00	8.93	6.00	8.93	6.00	8.62
		II	7.81	11.62	6.31	9.07	7.00	10.42	2.00	2.98	2.00	2.98	2.00	2.87
12	March	I	0.00	0.00	0.00	0.00	2.00	2.69	6.00	8.06	6.00	8.06	6.00	8.06
		II	10.63	14.29	8.44	11.34	5.00	6.72	2.00	2.69	2.00	2.69	2.00	2.69
	Total		113.09	154.44	117.49	160.26	86.58	118.69	119.00	162.71	119.00	162.71	119.00	162.30



## HG4

Name of the Hydro Generating Station: Stage - IV Power Station

DESIGN ENERGY AND PEAKING CAPABILITY (Monthwise)- PONDAGE/STORAGE TYPE STATIONS.

Installed Capacity : No.of Units X. MW = 2 x 30

	Year :		2014-15 (Actual)		2015-16 (Actual)		2016-17 (Estimated) April to September (Actual) October to March (Projected)		2017-18 (Projected)		2018-19 (Projected)		2019-20 (Projected)	
S.No.	Month	Units	Design Energy (Mus)	Continuous MW	Design Energy (Mus)	Continuous MW	Design Energy (Mus)	Continuous MW	Design Energy (Mus)	Continuous MW	Design Energy (Mus)	Continuous MW	Design Energy (Mus)	Continuous MW
1	April	I	3.24	4.50	3.82	5.31	9.97	13.85	5.00	6.94	5.00	6.94	5.00	6.94
		II	2.07	2.88	4.58	6.36	1.64	2.28	5.00	6.94	5.00	6.94	5.00	6.94
2	May	I	1.97	2.65	5.05	6.79	5.52	7.42	4.50	6.05	4.50	6.05	4.50	6.05
		II	3.46	4.65	4.29	5.77	5.83	7.84	4.50	6.05	4.50	6.05	4.50	6.05
3	June	I	0.43	0.60	5.32	7.39	9.09	12.63	5.50	7.64	5.50	7.64	5.50	7.64
		II	7.49	10.40	6.52	9.06	11.60	16.11	5.50	7.64	5.50	7.64	5.50	7.64
4	July	I	5.29	7.11	8.27	11.12	11.60	15.59	7.50	10.08	7.50	10.08	7.50	10.08
		II	6.91	9.29	7.61	10.23	15.39	20.69	7.50	10.08	7.50	10.08	7.50	10.08
5	August	I	9.39	12.62	12.88	17.31	10.76	14.46	14.00	18.82	14.00	18.82	14.00	18.82
		II	14.41	19.37	14.00	18.82	17.73	23.83	14.00	18.82	14.00	18.82	14.00	18.82
6	September	I	17.49	24.29	17.95	24.93	6.74	9.36	14.00	19.44	14.00	19.44	14.00	19.44
		II	11.74	16.31	19.08	26.50	13.62	18.92	14.00	19.44	14.00	19.44	14.00	19.44
7	October	I	9.20	12.37	13.47	18.10	12.50	16.80	12.50	16.80	12.50	16.80	12.50	16.80
		II	16.13	21.68	12.43	16.71	12.50	16.80	12.50	16.80	12.50	16.80	12.50	16.80
8	November	I	1.86	2.58	4.83	6.71	9.50	13.19	10.00	13.89	10.00	13.89	10.00	13.89
		II	8.16	11.33	6.09	8.46	9.50	13.19	10.00	13.89	10.00	13.89	10.00	13.89
9	December	I	9.08	12.20	5.02	6.75	6.50	8.74	7.00	9.41	7.00	9.41	7.00	9.41
		II	7.26	9.76	4.88	6.56	6.50	8.74	7.00	9.41	7.00	9.41	7.00	9.41
10	January	I	4.66	6.26	5.42	7.28	6.00	8.06	6.00	8.06	6.00	8.06	6.00	8.06
		II	4.61	6.20	5.03	6.76	6.00	8.06	6.00	8.06	6.00	8.06	6.00	8.06
11	February	I	5.97	8.88	4.59	6.59	5.00	7.44	5.50	8.18	5.50	8.18	5.50	7.90
		II	2.33	3.47	2.92	4.20	5.00	7.44	5.50	8.18	5.50	8.18	5.50	7.90
12	March	I	5.68	7.63	4.87	6.55	4.50	6.05	4.25	5.71	4.25	5.71	4.25	5.71
		II	4.69	6.30	6.04	8.12	4.50	6.05	4.25	5.71	4.25	5.71	4.25	5.71
	Total		163.52	223.33	184.96	252.35	207.49	283.54	191.50	262.07	191.50	262.07	191.50	261.50



Name of the Hydro Generating Station: Sonapani Hydro Project

DESIGN ENERGY AND MW CONTINUOUS(Monthwise) - RUN OF RIVER TYPE STATIONS

Installed Capacity : No.of Units X. MW = 1 x1.5

	Year :		2014-15 (Actual)		2015-16 (Actual)		2016-17 (Estimated) April to September (Actual) October to March (Projected)		2017-18 (Projected)		2018-19 (Projected)		2019-20 (Projected)	
S. No	Month	unit	Design Energy (Mus)	Continuous MW	Design Energy (Mus)	Continuous MW	Design Energy (Mus)	Continuous MW	Design Energy (Mus)	Continuous MW	Design Energy (Mus)	Continuous MW	Design Energy (Mus)	Continuous MW
1	April	1	0.18	0.25	0.36	0.50	0.42	0.58	0.20	0.28	0.20	0.28	0.20	0.28
2	May	1	0.69	0.96	0.64	0.89	0.69	0.96	0.28	0.39	0.28	0.39	0.28	0.39
3	June	1	0.81	1.13	0.47	0.65	0.81	1.13	0.48	0.67	0.48	0.67	0.48	0.67
4	July	1	0.56	0.78	0.18	0.25	0.79	1.10	0.59	0.82	0.59	0.82	0.59	0.82
5	August	1	0.67	0.93	0.15	0.21	0.81	1.13	0.68	0.94	0.68	0.94	0.68	0.94
6	September	1	0.80	1.11	0.73	1.01	0.80	1.11	0.70	0.97	0.70	0.97	0.70	0.97
7	October	1	0.71	0.99	0.74	1.03	0.51	0.71	0.64	0.89	0.64	0.89	0.64	0.89
8	November	1	0.62	0.86	0.63	0.88	0.45	0.63	0.56	0.78	0.56	0.78	0.56	0.78
9	December	1	0.52	0.72	0.48	0.67	0.41	0.57	0.44	0.61	0.44	0.61	0.44	0.61
10	January	1	0.42	0.58	0.53	0.74	0.40	0.56	0.39	0.54	0.39	0.54	0.39	0.54
11	February	1	0.32	0.48	0.39	0.56	0.31	0.43	0.26	0.39	0.26	0.39	0.26	0.37
12	March	1	0.36	0.50	0.38	0.53	0.26	0.36	0.27	0.38	0.27	0.38	0.27	0.38
	Total		6.66	9.28	5.68	7.91	6.66	9.23	5.49	7.65	5.49	7.65	5.49	7.64