

Technical Data as on 31.03.2020

Details	Units	Shillong Distirbution Circle	Khasi Hill Distirbution Circle	Ri Bhoi Distirbution Circle	Jaintia Hills Distirbution Circle	East Garo Hills Distirbution Circle	West Garo Hills Distirbution Circle
Number of Electrified Villages	No.	85	2045	933	537	259	225
Number of Consumers	No.	108410	128325	51379	73073	52787	50193
Number of 33/11 KV sub-station	No.	16	24	10	18	14	19
Capacity of 33/11 Kv Sub-Station	MVA	188.8	87.8	63.5	70.16	60.35	107.75
Length of 33 KV lines	Ckm	203.964	401.1	261.2	304.5	628.6	492.2
Number of 11/0.4 KV Sub-Station	No.	1257	2581	1293	1214	2266	2477
Capacity of 11/0.4 Kv Sub-Station	MVA	262.327	128.46	116.29	1744.26	86.38	117.078
Number of 11/0.24 KV Sub-Station	No.	11	71	27	132		53
Capacity of 11/0.24 Kv Sub-Station	MVA	165	0.66	0.38	81.299		0.647
Length of 11 KV lines	Ckm	702.7267	4198.56	1592.19	1918.26	3517.654	3315.539
Total No. of Distribution Transformer	No.	1268	2676	1320	1346	2266	2530
Number of failed Transformer	No.	25	217	65	92		
Length of LT Lines	Ckm	1339.621	3258.88	1779.59	1919.511	4697.472	8258.926

Executive Engineer
MIS Division
MePDCL, Shillong