



MEGHALAYA ENERGY CORPORATION LIMITED

OFFICE OF THE ADDITIONAL CHIEF ENGINEER (EL)

MATERIAL MANAGEMENT

LUM JINGSHAI; SHORT ROUND ROAD; SHILLONG-793001

Phone - 0364-2591930 E-mail: ace.mm.meecl@gmail.com Fax- 0364- 2590955

Revised Purchase, Estimate & Issue rates of 132KV, 33KV SF6 Circuit Breakers.

Sl No.	Item Description	Unit	Purchase Rate (₹)	Estimate rate inclusive of GST@18% & 5% F&I	Issue Rate inclusive of GST & Storage & handling Charges @7.5%
1	145 KV, 40KA, SF6 Circuit Breaker with breaking capacity of 2500 MVA and continuous rating of 800 Amps along with mounting structure & Bimetalic rigid type terminal connectors for connecting with ACSR Panther conductor DC volts 220V, CB with spray accessories, foundation bolts etc & also with first filling of SF6 gas.	Set	560000.00	693840.00	745878.00
2	36 KV, 1250A, SF6 Circuit Breaker 25KA, type 30SFPG with mounting structure & Bimetalic rigid type terminal connectors for connecting with ACSR Panther conductor DC volts 110V, CB with spray accessories, foundation bolts etc & also with first filling of SF6 gas.	Set	435000.00	538965.00	579387.38

Additional Chief Engineer(MM)

Dated 20-3-2021

Memo No. ACE(MM)/Approved-Rate/2019-20/27

Copy to:

- 1) The Director (Distribution), MePDCL, Shillong
- 2) The Director (Transmission), MePTCL, Shillong
- 3) The Director (Generation) MePGCL, Shillong
- 4) All Chief Engineer (MePDCL, MePTCL, MePGCL, RE, M&E), Shillong.
- 5) All Addl. Chief Engineer (T&T, Comm.EZ, WZ, P&D), Shillong/Tura.
- 6) All Superintending Engineer (KHDC, RBDC, JHDC, SDC, WGHDC, EGHDC), Shillong/Umiam/Jowai/Tura/Williamnagar. They are requested to circulate to concern Division.
- 7) All Superintending Engineer (T&T Tura, T&T Shillong) They are requested to circulate to concern Division.
- 8) The Executive Engineer(MM), Store, MeECL, Shillong.
- 9) The Executive Engineer, MIS, Shillong for updating in website.
- 10) The EDPA(MM) for updating.

Additional Chief Engineer(MM)