

Addendum-2

**Amendment to BID Document
Project for Renovation and Modernization of Umiam-Umtru Stage III Hydroelectric Power Station : Rehabilitation of Electro Mechanical Equipments (Volume-I of II)and (Volume-II of II)**

SI No		Page	Clause	Description of the existing bid	Amended to
1	Volume II of II SECTION VI	8	2.8. Outdoor Switchyard	j) Two-stage Lift (including required lighting) for movement of personnel and equipments to Switchyard	This may be deleted
		24	S.20.3	Two Stage Lift	This may be deleted
		104	Appendix 5 Item 28	28. Lift [from Power House to Switchyard] N. B.: The Power house is 285 steps from the Switchyard	This may be deleted
2	Vol II / Section VI	4	a) Employer's Requirements / List of Major Equipment's /1.1 (h)	Water lubricated bearing with suitable material for the bearing pads, such as Thordon SXL or equivalent	Water lubricated bearing with suitable material for the bearing pads, such as Thordon SXL or equivalent or newly design Oil Lubricated bearing
		12	b) S 2.1 (6) Replacement of guide bearings		