



No. MePTCL/CE (T)/TT-203/2025-26/50

Dated Shillong, the 25<sup>th</sup> August, 2025.

**CORRIGENDUM**

In line with clause 1.2.3 of section 1- Instructions to Bidders of bid documents for the tender invited vide Bid Identification No: MePTCL/CE(T)/NEHU/ 132/33 kV 50 MVA X-MER/2025 for “Manufacturing, Testing, Supply, Installation and Supervision of Commissioning of 132/33kV, 50 MVA Mineral Oil Filled Power Transformers and Related Services for 132 KV NEHU Grid Substation in Meghalaya”, the following is hereby notified for information to all the prospective bidders for preparing and submission of the bid proposals.

The Technical Particulars of 132/33kV, 50 MVA Power Transformer amended vide letter No. MePTCL/CE (T)/TT-203/2025-26/46, Dt. 20.08.2025 mentioned at Sl No 25 (ii) is hereby corrected as follows:

Sl. No.	Description	Unit	Existing Technical Parameters	Amended Technical Parameters
1	Maximum Permissible Losses of Transformers			
	Max. Load Loss at rated current and frequency and at 75°C at principal tap between HV & LV	kW	125	220

All other terms and conditions of the Bid Document will remain the same.

/

(P.Sun)

Chief Engineer (Transmission)

Memo No. MePTCL/CE (T)/TT-203/2025-26/50 (a)

Dated Shillong, the 25<sup>th</sup> August, 2025.

Copy to:

1. The Director (Transmission), MePTCL, Shillong for favour of information.
2. The Additional Chief Engineer, T&T, MePTCL, Shillong.
3. The Superintending Engineer, T&T Shillong Circle, MePTCL, Shillong.
- ✓ 4. The Executive Engineer (MIS), MePDCL, Shillong with a request to upload the Corrigendum in the MeECL websites.

Chief Engineer (Transmission)