



No. MePTCL/CE (T)/TT-190(Pt-I)/2025-26/67

Dated Shillong, the 26th August, 2025.

CORRIGENDUM

In line with clause 1.2.3 of section 1- Instructions to Bidders of bid documents for the tender invited vide Bid Identification No: *BID IDENTIFICATION No: MePTCL/CE(T)/NESIDS-OTRI 132 & 33 kV MAWLAI GIS/2025* for "Supply of 132kV and 33kV Indoor GIS and related services for Augmentation of 132/33kV Mawlai Substation from 3 x 20MVA to 3 x 50MVA in Meghalaya", the following is hereby notified for information to all the prospective bidders for preparing and submission of the bid proposals.

The Technical Particulars of 132/33kV, 50 MVA Power Transformer mentioned in Volume II Annexure-A-1 related to Technical Specification of 50 MVA Power Transformer is hereby amended as follows:

Sl. No.	Description	Unit	Existing Technical Parameters	Amended Technical Parameters
	Maximum Permissible Losses of Transformers			
	Max. Load Loss at rated current and frequency and at 75°C at principal tap between HV & LV	kW	125	220

All other terms and conditions of the Bid Document will remain the same.

(P.Sun)

Chief Engineer (Transmission)

Memo No. MePTCL/CE (T)/ TT-190(Pt-I)/2025-26/67 (a)

Dated Shillong, the 26th August, 2025.

Copy to:

1. The Director (Transmission), MePTCL, Shillong for favour of information.
2. The Additional Chief Engineer, T&T, MePTCL, Shillong.
3. The Superintending Engineer, T&T Shillong Circle, MePTCL, Shillong.
4. The Executive Engineer (MIS), MePDCL, Shillong with a request to upload the Corrigendum in the MeECL websites.

Chief Engineer (Transmission)