



Meghalaya Power Transmission Corporation Limited
Office of the Chief Engineer (Transmission)
Lumjingshai, Short Round Road, Shillong – 793001
CIN – U4010ML2009SGCO08393 email: cetranzemeptcl@gmail.com

No. MePTCL/CE (T)/TT-139/HTLS/2025-26/15

Dated Shillong, the 10th September, 2025.

CORRIGENDUM

In line with clause 1.2.3 of section 1- Instructions to Bidders of bid documents for the tender invited vide No. MePTCL/CE (T)/TT-139/HTLS/2025-26/11, Dated 20th August, 2025 and Bid Identification No. MePTCL/CE (T)/HTLS/2025 for "Re-conductoring and strengthening of 132 KV S/C Line by HTLS conductors and related services in Meghalaya (Line Length 10.41 ckt.km)", the Bill of Quantity of the tender is hereby amended as indicated below:

Sl No	Reference document	Existing Description of Materials	Amended Specifications
1	BOQ 1 (Sl No 16 & 17) & BOQ 4 (Sl No 15 & 16)	145kV, 1Phase CVT, 8800pf	145kV, CVT, 40kA, 4400pf
2		Wavetrap 800A with Tuning unit	Wavetrap 1250A, Short Circuit 40kA, Inductance 0.5mH with Tuning circuit.


The correction is to this extent only other terms and conditions remain the same.

(P.Sun)

Chief Engineer (Transmission)

Memo No. MePTCL/CE (T)/TT-139/HTLS/2025-26/15 (a) Dated Shillong, the 10th September, 2025.
Copy to:

1. The Director (Transmission), MePTCL, Shillong for favour of information.
2. The Addl. Chief Engineer (T&T), MePTCL, Shillong.
3. The Superintending Engineer, T&T RBJH Circle MePTCL, Shillong.
4. The Executive Engineer (MIS), MePDCL, Shillong with a request to upload the Corrigendum in the www.meghlayatenders.gov.in.


Chief Engineer (Transmission)

