



MePGCL

Generating Clean And Green Energy

MEGHALAYA POWER GENERATION

CORPORATION LIMITED



**GUIDELINES FOR RELEASE
OF WATER THROUGH THE
GATES OF THE
NEW UMTRUHE
PROJECT
CONCRETE DAM**

2026



**GUIDELINES FOR RELEASE OF WATER THROUGH
THE GATES OF THE NEW UMTRU HEP CONCRETE DAM**

1.0 - Introduction

1.1- Dams have been constructed across the Rivers to create artificial Lakes/Reservoirs for storing of water which is being utilized for generation of electricity, irrigation, drinking water etc. Sometimes due to heavy rain during rainy season, the discharge in the River can be so high that the water level in the Reservoir, if not controlled, can rise beyond the FRL. In such cases, the excess water from the Reservoir has to be released in a gradual and regulated manner through the Radial Gates of the Dams, to ensure that people on the downstream are not affected by the sudden rise of water level. This will also safeguard the Dams from being overtopped, which may endanger the abutments from being washed out, thereby causing loss of lives and properties.

Water from the Reservoir may also be required to be released through the Radial Gates at any time of the year as may be required by the Owner or due to emergency/crisis that may arise due to various reasons.

In view of this, all Radial Gates of Dams are required to be in operational mode 24x7.

2.0- Requirement of Guidelines for Radial Gates

2.1- The Guidelines for Operation of Radial Gates is needed by all entity/owner of Dams and Reservoirs as it is the guiding instrument at any time whenever Gates are required to be operated to release water from the Reservoir due to Flood, Sabotage, Natural disaster or any other crisis. The Guidelines for Operation of Gates also guides the Operator of the Radial Gate the process of releasing of water from the Reservoir in such a manner that;

- (i) The Dams and other related Hydraulic Structures are not put in any danger.
- (ii) The Reservoir is allowed to impound optimum quantity of water for economic generation of electricity.
- (iii) It mitigates the damage of flood downstream of the Dams.

2.2- The Guidelines help the owner to maintain the Radial Gates in operational mode 24x7.

2.3- The Guidelines for Operation of Radial Gates also provide;

- (i) Technical details of the Dam, Reservoir and Radial Gates.
- (ii) Mode of inspection, monitoring and reporting of the healthiness of the Dams, Reservoir and Radial Gates.
- (iii) Instruction to the Engineer-in-charge in regard to maintenance of the Gates, including operation of the Gates to facilitate release of water from the Reservoir whenever required.
- (iv) It also contains names, addresses and contacts of all stakeholders of the Dams.

3.0- New Umtru Reservoir and requirement for Controlled Release of Water through the Gates:-

New Umtru Reservoir receives water from the catchment of the Umtrew River and from the Tail water of Umiam-Umtru Stage-IV Power Station. The New Umtru Dam has 6(six) No. of Radial gates with a design flood of 3820 Cumec.

The reservoir can store water for about 3.55 MCM up to FRL of 130.10M. Downstream of the Concrete Dam, the River runs through Ravines of about 9.80 Km up to Byrnihat Bridge. On its way, there are few villages/developments on both banks, and invariably there are always human activities along the stretch of this River.

Since, New Umtru HEP is a Run of the River (ROR) Scheme with small Storage capacity which requires frequent release of water through the Radial Gates during Monsoon and Non-monsoon period during incessant rainfall, any release of water from the New Umtru Concrete gravity Dam has to be properly planned, estimated, and regulated and action needs to be taken instantly so as to avoid any untoward incident.

4.0- Name, Address & Contacts of the Owners of the Dams

4.1- Name & Address: Meghalaya Power Generation Corporation Limited,
Lumjingshai, Shillong-793001,
East Khasi Hills District, Meghalaya.

4.2- Contacts of responsible Persons:

Proforma-1

Sl. No	Name & Designation	Address		Telephone No.(Office)	MobileNo.	E-mailID
		Office	Resident			
1	2	3	4	5	6	7
1.	Shri. Sanjay Goyal , IAS, Chairman-cum- Managing Director	Me.E.C.L, Lumjingshai, Shillong- 793001.	-	0364-2590367 0364-259063 (F)		sanjaygoyal.ias@gmail.com
2.	Shri Richard Yanthan, IAS, Director Corporate Affairs	Me.E.C.L, Lumjingshai, Shillong- 793001.	-	0364-2591992		
3.	Shri. K. Thangkhiew Director, (Generation) MePGCL, Shillong.	Me.P.G.C.L, Lumjingshai, Shillong- 793001.	-	0364-2591406	7005093571 9856370407	pce_meecl@yahoo.co.in
4.	Smti. A.Sunn, Chief Engineer(C), HP&HC, MePGCL, Shillong.	Me.P.G.C.L, Lumjingshai, Shillong- 793001.	-	0364-2590113	9402309525	cehphc.mepgcl@gmail.com
5.	Shri.E.Marap , Chief Security Officer	Me.E.C.L, Lumjingshai, Shillong- 793001.	-	-	8974158543	-
6.	Smti.L.M.Kharkamni, Executive Engineer (C), Dam Safety Cell, MePGCL, Shillong.	O/o Chief Engineer(C), HP&HC, Me.P.G.C.L, Shillong -793001		0364-2590226	9774820349	eedamsafetymsh@gmail.com

5.0- SALIENTFEATURES:-

5.1- DAMS:-

Type of Dam:	CONCRETE GRAVITY
Height of Dam:	28.38m
Length of Dam:	(104.40+86.68+85.60) 276.68m
F.R.L	130.10m
M.W.L:	132.78m
M.D.D.L	124.50m
Crest Level:	124.00m

Top of Gates: 130.30m
Spillway capacity: 3820.00Cumec

5.2- RESERVOIR:-

Catchment Area: 1020 Sq.km
Water Spread Area at FRL: 0.537Sq.Km
Storage Capacity:
(i) *Live Storage:* 2.35Mcm
(ii) *Dead Storage:* 1.16Mcm
(iii) *Gross Storage:* 3.55Mcm
(iv) *Storage at EL 128.00M* 2.515Mcm

5.3- RADIAL GATES:-

No. of Gates: 6Nos.
Types: Radial Gates (Tainter)
Size: 13.40M X 7.00M (each gate)
Mode of operation: Electrically operated
(Provision available for Hand operation in emergency cases)
Brake:- Hydraulic operated brake
Company made: Electro Mechanic
Gate Operation:-
Minimum: 1 gate and 0.20m Opening.
Maximum: 6(six) No. of gates and 6.10m Opening each.

6.0- Inspection, Testing of Radial Gates including Gate Reporting.

6.1- Components of Radial Gates

I) GATES:

a) *Gate leaf:* Curve face plate
b) *Seals:* P-shaped
c) *Seal seat:* Stainless steel

II) HOISTINGARRANGEMENT:

a) *Drum Hoist:* Rope Drum Hoist with D/s. Suspension
b) *Ropes:* 32mmø Wire Rope
c) *Capacity of motor:* 11KW(15H.P)each
d) *Type of brake:* Hydraulic operated brake
e) *Hoisting Capacity of Single Gate:* 70tonne each

6.2- All the Radial Gates including its components and accessories are to be inspected and tested at least once in a month.

8.1.2-Outgoing Message:-

Proforma-3

Sl. No.	Date	Time	To whom Sent including Contact No.	Content of the Message	Name & Signature of sender	Remarks
1	2	3	4	5	6	7
1						
2						

The messages both incoming and outgoing are to be compiled and forwarded to the higher authority on daily basis.

9.0- Contact Persons for New Umtru Reservoir

The following persons are to be contacted through Telephone, SMS, E-mail before the release of water from the Reservoir.

9.1-Incharge of the Dams:-

Proforma-4

Sl. No.	Names & Designation	Address		Telephone No. (office)	Mobile No.	E-mail ID
		Office	Residence			
1	2	3	4	5	6	7
1.	Shri.C.Pariat Superintending Engineer(C), HSM, Me.P.G.C.L, Shillong.	SE,(C), HSM Circle, MePGCL, Lumkshaid, Shillong-793002	-	0364-2547878	8731096843	hcmshp16@gmail.com
2	Shri. R. Pakyntein, Executive Engineer (C),	New Umtru Civil Division, MePGCL, Dehal, Byrnihat.			9615136794	refillpakyntien@gmail.com
3	Shri.T. Bamon, Assistant Executive Engineer (C)	New Umtru Civil Sub-Division - III, MePGCL, Dehal Byrnihat			8119098554	tarun.moral@gmail.com
4	Shri. D. Lyngdoh, Junior Engineer(C)	O/O New Umtru Civil Sub-Division -III, MePGCL, Dehal, Byrnihat			8414808890	lyngdohdennybert@gmail.com
5	Shri. R.L. Nongkynrih, Junior Engineer(C)	O/O New Umtru Civil Sub-Division -III, MePGCL, Dehal, Byrnihat			9615727665	rangkilyngdoh@gmail.com
6	Shri. S. Shabong Security Incharge Dehal, Byrni hat	New Umtru Dam			8974629550	

9.2- Contacts of important State Government, Officials including Police & Other Stakeholders.

Proforma-5

Sl. No.	Names & Designation	Address		Telephone No.	Mobile No.	E-mail ID
		Office	Residence			
1	2	3	4	5	6	7
1.	Dr. Shakil P.Ahammed, IAS, Chief Secretary and State Vigilance Commissioner	Meghalaya Secretariat Building Shillong 793001		0364-2224801 S-2250		cso-meg@nic.in
2.	Shri.Abhilash Baranwal, IAS, Deputy Commissioner & Chairperson (DDMA)	O/o the Deputy Commissioner, Ri-Bhoi District, Nongpoh		03638-299960 Fax 03638-232503		dc-rb-meg@nic.in
3.	Smti. B.Ranee, MCS, Addl. Deputy Commissioner & CEO (DDMA)	O/o the Deputy Commissioner, Ri-Bhoi District, Nongpoh		Fax 03638-232503	-	dc-rb-meg@nic.in
4.	Shri.Giri Prasad M, IPS Superintendent of Police	O/O the Superintendent of Police : Ri-Bhoi District HQ:Nongpoh, Meghalaya Pin Code- 793102		03638-232304 Fax 03638-232230	-	sp.rb-meg@nic.in
5.	Shri. Eric Kevin Dkhar, BDO Umling C&RD Block	Umling C&RD Block		03638-264234	9362548336	megumlingblock@gmail.com
6.	Shri. Andrew. L. Myrthong, BDO Umsning C&RD Block	Umsning C&RD Block		03638-262213	7085288659/ 8259074759/ 9402191280	meg-umsning@nic.in
7.	Dr. R.Talang., BDO Bhoirymbong C&RD Block	Bhoirymbong, C&RD Block			7085123373/ 8837360822	bhoirymbong.crd.block@gmail.com
8.	Directorate Information and Public relations,	Lower Lachumiere, Shillong-793003		0364-2224617		diprmeg@gmail.com
9.	Shri. Derrick.P.Pariat, Head of the Programme	Laitkor, NH 44, Shillong, Meghalaya 793010, India.		0364-2580319	9436105194	ddkshillong@gmail.com
10.	All India Radio, Shillong -793001	Lower Lachumiere, Shillong-793003		0361-2224153 Fax 0361-2224153		airshill@gmail.com airshill@air.rg.in
11.	The DC/Adjutant For Commandant 1 st Bn NDRF, Ministry of Home Affairs,	Patgaon, PO:Azara, Guwahati, Assam-781017		0361-2840284	9435545949 (officialmobile number) Control room no.- 7637011337 9435417246	assam01-ndrf@nic.in

9.3- Contacts of Prominent Persons residing along the River Downstream of the new Umtru Dam who may be affected due to release of excess water through the Gates of the Dam.

Proforma-6

Sl No	Name of the Villages	Designation
1	Narbong	8974424381/8974424382
2	Panitola	8730938304
3	Jojwa	7005036572
4	Upper Balian	7005259099
5	Lower Balian	8974235633
6	Jojwabil	8730080634
7	Rubber Khuli	9383201245
8	Kongkhakhuli	8730938291
9	Umjojwa	7005036572/8794452147
10	Lower Amjok	6009138293
11	Amphangree	7005784465
12	Borbhuin	8131986020
13	Byrnihat	9436108888
14	Harli Bagan	9862306090
15	Matchokgre	8787610166
16	Nongkylla Khasi	9862856184
17	Nongrim Byrni	8787816454
18	Rongsakona	8794068134
19	Ronghona	9862858057
20	Upper Amjok	8131326645
21	Upper Bagan	8730856302
22	Ampher	8974344151
23	Dehal Bagan	8131049936
24	Nongkylla Mikir	8794944161
25	Raja Bagan	8837498988
26	Temulkhusi	7005675574
27	Sokurbill	9362695023

10.0- Preparation, Warning & Release of Water:-

Preparation, Warning and release of water from the Reservoir maybe done under two conditions i.e., Normal condition and emergency/crisis condition.

10.1- Under Normal condition:- Under this condition the water may have to be released during Monsoon Period due to high flood or during Non - Monsoon Period as may be required.

10.1.1-During Monsoon Period:-

- (a) When the pre-monsoon rain with heavy showers start in the month of May-June or before that, warning of likely release of excess water should be issued.
- (b) The Warning will be notified by the In-charge through sms and in writing to the District authorities and stakeholders.
- (c) A copy of the notification of the warning for likely release of excess water from New Umtru Dam should be sent to all Officers concerned within Me.E.C.L, Me.P.G.C.L, Me.P.D.C.L, Me.P.T.C.L and also to (1) Deputy Commissioner, Nongpoh (2) Superintendent of Police, Nongpoh (3) BDO, Umsning, Jirang, Umling (4) DIPR (5) Print & Electronic Media, and (6) All Concerned and stake holders residing or undertaking activities along the Umtrew River downstream of the New Umtru Dam to provide advance information and to restraint from any activities along the bank of the Umtrew river.
- (d) All materials, equipment required for Gate Operation are to be checked and made ready for operation.
- (e) 24hours operational duty is to be enforced as soon as the pre-monsoon starts.
- (f) **Release of Excess Water: -**

When the concerned authority authorizes release of water through the Gates, the following actions are to be taken:-

- (i) The decision to release water shall be taken at least one hour before the actual operation of the Radial Gates and actual release of water. The initial decision to release water through the Gates is to be taken by the Engineer In-charge with information to the higher authorities.
- (ii) The Siren installed on the deck of the gates is to be blown for a duration not less than 30 (thirty) minutes before releasing of water.
- (iii) Simultaneously, information of release of water should be sent through Telephone, SMS, Whatsapp, etc. to all concerned and stake holders as recorded in **Performa 1, 4, 5 & 6** and record the same as indicated in **Performa 2 & 3**.
- (iv) Minimum 15 minutes after blowing the Siren, initially one gate can slowly be opened and may be raised up to a height of not less than 300mm
- (v) In case, there is requirement to enhance the release of water due to high inflow, more gates may be opened. The Gates may be increased by 300mm one gate every half an hour or hourly as the case may be and as decided by the Engineer-in-charge.
- (vi) In case of decrease of inflow into the Reservoir and other consideration, the size of opening of the Gates should be reduced accordingly.
- (vii) The decision to increase or decrease the size of opening of the gates or closing the gates may be taken by the Engineer-in-charge of the Dam with intimation to the higher authority.

- (viii) *In all circumstances, water should not be allowed to overtop the Radial Gates.*
- (ix) *The water level of the Reservoir should not be allowed to go beyond the restricted water level of the Reservoir.*
- (x) *In all circumstances the water level in the reservoir should always **maintain at FRL ie 130.10m** Except when **the inflow is very high the water level may be kept 1(one)ft below FRL***

10.1.2- During Non - Monsoon Period:-Non-Monsoon Period means the period when the water level of the Reservoir is below 128.00m and the inflow into the Reservoir is not likely to overtop the Radial gates.

10.1.2.1- *Under Normal conditions, the water is usually not required to be released through the gates during Non-Monsoon Period. However, there may be times that release of water may have to be done during this period to enable the owner to take up necessary repairs of any Hydraulic Structure or de- silting of the reservoir near the Intake or for any other reasons. Such release needs the approval of the higher authority, and in consultation with the Chief Engineer(Generation) and State Load Dispatch Centre. When the authority concerned decided to release water through the Gates under any of these conditions, the following action is to be taken:-*

- (a) *The quantity of water to be released, the rate of discharge through the gates and the time period of release are to be properly calculated and planned to avoid unwanted situations along the river course on the downstream of the Dam.*
- (b) *The Warning will be notified by the In-charge through sms and in writing to the District authorities and stakeholders.*
- (c) *A copy of the notification of the warning for likely release of excess water from New Umtru Dam should be sent to all Officers concerned within Me.E.C.L, Me.P.G.C.L, Me.P.D.C.L, Me.P.T.C.L and also to (1) Deputy Commissioner, Nongpoh (2) Superintendent of Police, Nongpoh (3) BDO, Umsning ,Jirang, Umling (4) DIPR (5) Print & Electronic Media, and (6) All Concerned and stake holders residing or undertaking activities along the Umtrew River downstream of the New Umtru Dam to provide advance information and to restraint from any activities along the bank of the Umtrew river.*
- (d) *All materials, equipment required for Gate Operation are to be checked and made ready for operation.*
- (e) *One hour before release of water through the Gates, a warning is to be sounded by blowing the siren installed on the Deck of the Gates. Simultaneously information of release of water should be sent through Telephone, SMS, Whatsapp, etc. to all concerned and stake holders as recorded in **Performa 1, 4, 5 & 6** and record the same as indicated in **Performa 2 & 3.***
- (f) *After blowing the siren, initially one gate can slowly be opened and may be raised up to a height of not less than 1ft.*


- (g) *After the initial release of one hour, another gate may be opened. The size of opening of the Gate may be increased by 1ft for 1 (one) Gate every 1 hour up to the required size of opening as per schedule.*
- (h) *All Gates should be closed as soon as the targeted quantity of water is released or the required water level of water in the Reservoir is achieved.*
- (i) *In all circumstances the water level in the reservoir **should always maintain at FRL ie 130.10m** during non-monsoon period. **The office of the Assistant Executive Engineer (C), NUCSD, MePGCL, Dehal, Byrnihat which directly deals with maintenance of water level shall strictly adhere to the Guidelines.***

10.2.0- Under Crisis/Emergency condition: - Water may be released at any time of the year in case of the emergency/crisis situation that may arise due to;

- (a) *Sudden and unprecedented heavy and very heavy rainfall in the catchment causing very high and unexpected flooding of the Reservoir.*
- (b) *Breaking of the Dam due to structural failure, earthquake, sabotage and other.*
- (c) *Failure of other hydraulics structure like Tunnel, Dykes and other.*
- (d) *Any other reasons that require urgent release of water.*

10.2.1- The Engineer-in-charge, after satisfying his/her self that the crisis/emergency condition warranted urgent release of water through the Gates of the Dam, will immediately inform the controlling Officers and Chief Engineer concerned, who will order for immediate release of water and inform the same to the higher authority of the Corporation. When the decision to release water is communicated (verbally or officially) the following steps are to be taken;

- (i) *The Siren installed on the deck of the gates is to be blown for duration not less than half an hour.*
- (ii) *Simultaneously information of release of water should be sent through Telephone, SMS, Whatsapp, etc. to all concerned and stake holders as recorded in **Performa 1, 4, 5 & 6** and record the same as indicated in **Performa 2 & 3***
- (iii) *After blowing the siren, initially one gate can be opened and may be raised upto a height of not less than 1ft.*
- (iv) *Depending on the situation of emergency/crisis the size of opening of the Gates, the number of gates and the Discharge of water to be released will be decided by the Chief Engineer(C), HP&HC, Me.P.G.C.L, in consultation with Director (Generation) Me.P.G.C.L, Shillong and to accordingly intimate the CMD, Me.P.G.C.L.*
- (v) *During emergency/crisis situation the In-charge and other higher officials are to be present at the place/site of event (Ground Zero).*


DIRECTOR (GENERATION)