



Meghalaya Power Transmission Corporation Limited
Office of the Chief Engineer (Transmission)
Lumjingshai, Short Round Road, Shillong – 793001
CIN – U4010ML2009SGC008393 email: cetranzemeptd@gmail.com

No. MePTCL/CE(T)/TT-139/ HTLS/2026-27/78

Dated: 20th July, 2026

CORRIGENDUM No. 1

In line with clause 1.2.3 of section 1- Instructions to Bidders of bid documents for the tender invited vide No. MePTCL/CE(T)/HTLS/2026 Dated: 12th June, 2026 for 'Re-Conductoring and Strengthening of the 132 kV Single Circuit Transmission Line by High Temperature Low Sag (HTLS) conductor and Related Services (Line length 28.96 CKM)" amendments to the following clauses is hereby notified for information to all the prospective bidders for preparing and submission of the bid proposals.

Clause	Existing	Amendment
Section-1 ITB 1.3.9.2	1.3.9.2. The bid security shall be a demand guarantee, in the form of an unconditional bank guarantee from a Scheduled or Nationalized Bank. The bid security shall be submitted using the 'Bid Security Form' included in Section 2 (Bidding Forms). The form must include the complete name of the Bidder. The bid security shall be valid for ninety days (90) beyond the original validity period of the bid, or beyond any period of extension if requested under <i>ITB Clause 1.3.8.2</i>	1.3.9.2. The bid security shall be a Bank uarantee, in the form of an unconditional bank guarantee from a Scheduled or Nationalized Bank. The bid security shall be submitted using the 'Bid Security Form' included in Section 2 (Bidding Forms). The form must include the complete name of the Bidder. The bid security shall be valid for ninety days (90) beyond the original validity period of the bid, or beyond any period of extension if requested under <i>ITB Clause 1.3.8.2</i>
APPENDIX to ITB-1 ITB 1.1.2.4	1.3 b) Minimum Average Annual Turnover* (MAAT) for best three years i.e. 36 months out of last five financial years of the bidder should be not less than Indian Rs. 8.40	1.3 b)Minimum Average Annual Turnover* (MAAT) for best three years i.e. 36 months out of last five financial years of the bidder should be not less than Indian Rs. 8.50



Meghalaya Power Transmission Corporation Limited

Office of the Chief Engineer (Transmission)

Lumjingshai, Short Round Road, Shillong – 793001

CIN – U4010ML2009SGC008393

email: cetranzemeptd@gmail.com

	Crore for this package.	Crore for this package.
APPENDIX to ITB-1 ITB 1.3.9.1	The Bidder shall furnish a bid security in the amount of Rs.60.00 Lakhs in favour of MePTCL, Principal Account, Payable at Shillong.	The Bidder shall furnish a bid security in the amount of Rs.60.00 Lakhs in favour of MePTCL, Principal Account, Payable at Shillong. In case of JV the Bid Security shall be furnished by the lead partner.
APPENDIX V to ITB-2 1.3	Time Schedule Time to complete Works from the Commencement Date specified in Article 3 of the Contract Agreement for determining time for commissioning is 8 (eight) months. Bids not meeting the above time schedule shall be rejected. However, no credit will be given for earlier completion.	Time Schedule Time to complete Works from the Commencement Date specified in Article 3 of the Contract Agreement for determining time for commissioning is 8 (eight) months from the date of issuing the LoA. Bids not meeting the above time schedule shall be rejected. However, no credit will be given for earlier completion.
APPENDIX V to ITB-2 2.5.1	Subcontractors/manufacturers for the following major items of supply must meet the following minimum criteria, herein listed for that item. Failure to comply with this requirement will result in rejection of the subcontractor/manufacturer. The bidder shall possess required equipments, tools & tackles to carry out the work.	Subcontractors/manufacturers for the following major items of supply must meet the following minimum criteria, herein listed for that item. Failure to comply with this requirement will result in rejection of the subcontractor/manufacturer. The bidder shall possess required equipments, tools & tackles to carry out the work.



Meghalaya Power Transmission Corporation Limited

Office of the Chief Engineer (Transmission)

Lumjingshai, Short Round Road, Shillong – 793001

CIN – U4010ML2009SGC008393

email: cetranzemeptcl@gmail.com

	<table><tr><th>Item No.</th><th>Description of Item</th><th>Minimum Criteria to be met</th></tr><tr><td>1</td><td>Manufacture of HTLS (equivalent to ACSR Panther Conductor)</td><td rowspan="3">The Bidder or if the Bidder is not a manufacturer of listed items his supplier must have designed, manufactured; type tested, supplied listed equipment, which are in successful operation for at least three (3) years as on the date of bid opening. The bidder/manufacturer should list such works executed to substantiate the requirement of this Clause using Form EXP-2.</td></tr><tr><td>2</td><td>Manufacture of long rod insulators suitable for stringing of above mentioned HTLS conductor.</td></tr><tr><td>3</td><td>Manufacture of hardware fitting suitable for above mentioned HTLS conductor</td></tr></table>	Item No.	Description of Item	Minimum Criteria to be met	1	Manufacture of HTLS (equivalent to ACSR Panther Conductor)	The Bidder or if the Bidder is not a manufacturer of listed items his supplier must have designed, manufactured; type tested, supplied listed equipment, which are in successful operation for at least three (3) years as on the date of bid opening. The bidder/manufacturer should list such works executed to substantiate the requirement of this Clause using Form EXP-2.	2	Manufacture of long rod insulators suitable for stringing of above mentioned HTLS conductor.	3	Manufacture of hardware fitting suitable for above mentioned HTLS conductor
Item No.	Description of Item	Minimum Criteria to be met									
1	Manufacture of HTLS (equivalent to ACSR Panther Conductor)	The Bidder or if the Bidder is not a manufacturer of listed items his supplier must have designed, manufactured; type tested, supplied listed equipment, which are in successful operation for at least three (3) years as on the date of bid opening. The bidder/manufacturer should list such works executed to substantiate the requirement of this Clause using Form EXP-2.									
2	Manufacture of long rod insulators suitable for stringing of above mentioned HTLS conductor.										
3	Manufacture of hardware fitting suitable for above mentioned HTLS conductor										
APPENDIX V to ITB-2 2.5.1	Subcontractors/manufacturers for the following major items of supply must meet the following minimum criteria, herein listed for that item. Failure to comply with this requirement will result in rejection of the subcontractor/manufacturer. The bidder shall possess required equipments, tools & tackles to carry out the work.										

	<table><tr><th>Item No.</th><th>Description of Item</th><th>Minimum Criteria to be met</th></tr><tr><td>1</td><td>Manufacture of HTLS (equivalent to ACSR Panther Conductor)</td><td rowspan="3">The Bidder or if the Bidder is not a manufacturer of listed items should ensure the manufacturer supplying the listed items, to have designed, manufactured, type tested, supplied listed equipment, which have been in successful operation for at least six (6) months as on the date of bid opening. The bidder/manufacturer should list such works executed to substantiate the requirement of this Clause using Form EXP-2.</td></tr><tr><td>2</td><td>Manufacture of long rod insulators suitable for stringing of above mentioned HTLS conductor.</td></tr><tr><td>3</td><td>Manufacture of hardware fitting suitable for above mentioned HTLS conductor</td></tr></table>	Item No.	Description of Item	Minimum Criteria to be met	1	Manufacture of HTLS (equivalent to ACSR Panther Conductor)	The Bidder or if the Bidder is not a manufacturer of listed items should ensure the manufacturer supplying the listed items, to have designed, manufactured, type tested, supplied listed equipment, which have been in successful operation for at least six (6) months as on the date of bid opening. The bidder/manufacturer should list such works executed to substantiate the requirement of this Clause using Form EXP-2.	2	Manufacture of long rod insulators suitable for stringing of above mentioned HTLS conductor.	3	Manufacture of hardware fitting suitable for above mentioned HTLS conductor
Item No.	Description of Item	Minimum Criteria to be met									
1	Manufacture of HTLS (equivalent to ACSR Panther Conductor)	The Bidder or if the Bidder is not a manufacturer of listed items should ensure the manufacturer supplying the listed items, to have designed, manufactured, type tested, supplied listed equipment, which have been in successful operation for at least six (6) months as on the date of bid opening. The bidder/manufacturer should list such works executed to substantiate the requirement of this Clause using Form EXP-2.									
2	Manufacture of long rod insulators suitable for stringing of above mentioned HTLS conductor.										
3	Manufacture of hardware fitting suitable for above mentioned HTLS conductor										
	Subcontractors/manufacturers for the following major items of supply must meet the following minimum criteria, herein listed for that item. Failure to comply with this requirement will result in rejection of the subcontractor/manufacturer. The bidder shall possess required equipments, tools & tackles to carry out the work.										



Meghalaya Power Transmission Corporation Limited

Office of the Chief Engineer (Transmission)

Lumjingshai, Short Round Road, Shillong – 793001

CIN – U4010ML2009SGC008393

email: cetranzemepd@gmail.com

	<table><tr><th>Item No.</th><th>Description of Item</th><th>Minimum Criteria to be met</th></tr><tr><td>4</td><td>Manufacture of Current Transformer</td><td rowspan="3">The Bidder or if the Bidder is not a manufacturer of listed items his supplier must have designed, manufactured; type tested, supplied listed equipment, which are in successful operation for at least three (3) years as on the date of bid opening. The bidder/manufacturer should list such works executed to substantiate the requirement of this Clause using Form EXP-2.</td></tr><tr><td>5</td><td>Manufacture of Capacitive Voltage Transformer</td></tr><tr><td>6</td><td>Manufacture of Wave trap</td></tr></table>	Item No.	Description of Item	Minimum Criteria to be met	4	Manufacture of Current Transformer	The Bidder or if the Bidder is not a manufacturer of listed items his supplier must have designed, manufactured; type tested, supplied listed equipment, which are in successful operation for at least three (3) years as on the date of bid opening. The bidder/manufacturer should list such works executed to substantiate the requirement of this Clause using Form EXP-2.	5	Manufacture of Capacitive Voltage Transformer	6	Manufacture of Wave trap
Item No.	Description of Item	Minimum Criteria to be met									
4	Manufacture of Current Transformer	The Bidder or if the Bidder is not a manufacturer of listed items his supplier must have designed, manufactured; type tested, supplied listed equipment, which are in successful operation for at least three (3) years as on the date of bid opening. The bidder/manufacturer should list such works executed to substantiate the requirement of this Clause using Form EXP-2.									
5	Manufacture of Capacitive Voltage Transformer										
6	Manufacture of Wave trap										
ITB 1.1.2.4	1.2 (i) The bidder should have successfully completed* physical construction of transmission line project(s) involving stringing of not less than following cumulative route length of 50KM of 132 kV or higher voltage class transmission line as a prime contractor or as a partner in a joint venture+ within the last seven (7) years as on the originally scheduled last date of bid submission (soft copy) mentioned above. # Successfully completed means Certificate issued by the Power utility certifying the										

	<table><tr><th>Item No.</th><th>Description of Item</th><th>Minimum Criteria to be met</th></tr><tr><td>4</td><td>Manufacture of Current Transformer</td><td rowspan="3">The Bidder or if the Bidder is not a manufacturer of listed items should ensure the manufacturer supplying the listed items, to have designed, manufactured, type tested, supplied listed equipment, which have been in successful operation for at least three (3) years as on the date of bid opening and are compatible with the specifications of the HTLS conductor supplied. The bidder/manufacturer should list such works executed to substantiate the requirement of this Clause using Form EXP-2.</td></tr><tr><td>5</td><td>Manufacture of Capacitive Voltage Transformer</td></tr><tr><td>6</td><td>Manufacture of Wave trap</td></tr></table>	Item No.	Description of Item	Minimum Criteria to be met	4	Manufacture of Current Transformer	The Bidder or if the Bidder is not a manufacturer of listed items should ensure the manufacturer supplying the listed items, to have designed, manufactured, type tested, supplied listed equipment, which have been in successful operation for at least three (3) years as on the date of bid opening and are compatible with the specifications of the HTLS conductor supplied. The bidder/manufacturer should list such works executed to substantiate the requirement of this Clause using Form EXP-2.	5	Manufacture of Capacitive Voltage Transformer	6	Manufacture of Wave trap
Item No.	Description of Item	Minimum Criteria to be met									
4	Manufacture of Current Transformer	The Bidder or if the Bidder is not a manufacturer of listed items should ensure the manufacturer supplying the listed items, to have designed, manufactured, type tested, supplied listed equipment, which have been in successful operation for at least three (3) years as on the date of bid opening and are compatible with the specifications of the HTLS conductor supplied. The bidder/manufacturer should list such works executed to substantiate the requirement of this Clause using Form EXP-2.									
5	Manufacture of Capacitive Voltage Transformer										
6	Manufacture of Wave trap										
	1.2 (i) The bidder should have successfully completed* physical construction of transmission line project(s) involving stringing of conductors other than HTLS conductor not less than following cumulative route length of 50KM of 132 kV or higher voltage class transmission line as a prime contractor or as a partner in a joint venture+ within the last three (3) years as on the originally scheduled last date of bid submission (soft copy) mentioned above. # Successfully completed means Certificate issued by the Power utility certifying										



Meghalaya Power Transmission Corporation Limited

Office of the Chief Engineer (Transmission)

Lumjingshai, Short Round Road, Shillong – 793001

CIN – U4010ML2009SGC008393

email: cetranzemeptcl@gmail.com

	completion without any adverse remark.	the completion without any adverse remark.
--	---	---

/


(A.Majaw)
Chief Engineer (Transmission)

Memo. No. MePTCL/CE(T)/TT-139/ HTLS/2026-27/72a

Dated: 20th July, 2026

Copy to:

1. The Director (Transmission), MePTCL, Shillong for favour of information.
2. The Addl. Chief Engineer (T&T), MePTCL, Shillong.
3. The Superintending Engineer, T&T RBJH Circle, MePTCL, Shillong.
4. The Executive Engineer (MIS), MePDCL, Shillong with a request to upload the Corrigendum in the www.meghlayatenders.gov.in.


Chief Engineer (Transmission)